

The Channel Sensor Tap

TSL.C.051

Wall mounted sensor operated tap with robust body construction for all types of projects. Available mains. To be used in conjunction with the Channel dryer and soap dispenser for optimum efficiency.

| Finish | Codes | LRV* |
|-------------------------|--------------|------|
| Satin | TSL.C.051.CS | 58 |
| Black | TSL.C.051.BK | 3 |
| Brass | TSL.C.051.BR | 40 |
| Copper | TSL.C.051.CP | 19 |
| Chrome | TSL.C.051.C | 75 |
| | | |

Light Reflectance Value*











UK: +44 (0) 333 200 8131 www.thesplashlab.co.uk info.uk@thesplashlab.com Making the ordinary, extraordinary

Technical Data

| Minimum operating pressure | 7 - 87 psi dynamic pressure | |
|----------------------------|--|--|
| Flow rate | 1.89 LPM (Other flow rates available upon request) | |
| Weight | 1.2kg | |
| Stainless steel grade | 316 Stainless steel | |
| Sensor Range | Preset 120±20mm (adjustable). Min range 50mm - Max range 150mm | |
| Comfort Delay | 2 seconds | |
| Power supply - mains | Input: 100-240V ac; 50/60Hz Output: 6V DC; 0.5A,3W max | |
| Security Cut-off | 60 seconds | |
| IP Rating | IP35 | |
| | | |

Installation requirments

| Wall cut-out (dia) | Ø30mm | |
|------------------------|---|--|
| Maximum wall thickness | 50mm | |
| Anti-rotation collar | Included | |
| Reflective surfaces | Not to be installed above highly polished basins, or waste outlets | |
| Access requirements | Solenoids and transformers must be accessible at all times for servicing | |
| Cabling | Low voltage push fit connector to tap | |
| Power supply | For the mains power option, it is recommended that the sensors are installed on their own circuit to avoid interference from other power demands. | |
| Recommended Spacing | If the Chanel Tap is installed with other units from the Channel System, it should be installed in the centre with the advised spacing of 150mm to the left for the Soap Dispenser and 200mm to the right for the Hand Dryer. | |

Compliance & certificates

| ASME A112.18.1, CSA B125.1 | Compliant for assessment for Water Saving and Efficiency criteria |
|----------------------------|---|
| NSF/ANSI/CAN 61 | Certificate 1506314 |
| WRAS | Certificate 1.42/20608 |
| CE | Certificate 04/00125 |
| UKCA | |
| RoHS | |
| BREAAM | 5 Credits |
| | |

UK: +44 (0) 333 200 8131 www.thesplashlab.co.uk info.uk@thesplashlab.com Making the ordinary, **extraordinary**

Included

Channel sensor tap head

Mains power supply

Solenoid valve

Pad

Gasket

Washer

Fixing nut

Flow restrictor

Flex hose - 300mm

⁺ Technical drawing **FRONT** SIDE 550mm

Warranty & Spare parts

For warranty terms and conditions please visit www.thesplashlab.com If additional spare parts are required and are not listed above, please contact us at info.uk@thesplashlab.com

| Part | Codes |
|----------------|-------------|
| Solenoid Valve | TSLP.310014 |
| AC Adaptor | TSLP.230309 |

Related products



The Channel Soap Dispenser TSL.C.041

info.uk@thesplashlab.com

TSL.TSL.C.061

The Channel Hand Dryer

UK: +44 (O) 333 200 8131