

TSL + HERITAGE

DATASHEET

L980

Sensor
Tap

The simply designed 980 series is suitable for all types of washroom installations due to its robust build quality. This series is available with a temperature controlled option, and with a choice of mains or battery power options.



CODES	POWER SUPPLY	TEMPERATURE CONTROL	WEIGHT
L982	Mains	Pre-mixed	1.66Kg (3lb 11oz)
L984	Mains	Two water inlets	1.66Kg (3lb 11oz)

TECHNICAL DATA

Finishes	C (Chrome) / CS (Satin)
Min/Max operations pressure	0.5 - 8 bar dynamic pressure
Flow rate	4 litres per minute (1 GPM (US)) standard. Options for 1.89 and 6 litres per minutes (0.5 and 1.59 GPM (US)) available Aerator Cascade
Warranty	2 years from date of purchase.
Sensor range (adjustable)	Preset 220mm (8 $\frac{21}{32}$ "). Min range 80mm (3 $\frac{5}{32}$ ") - Max range 300mm (11 $\frac{13}{16}$ ")
Security cut-off	90 seconds
Hot water temperature	Max 70°C (158°F)
Power supply	Mains - IP67 rated transformer with push-fit cabling to tap Battery - IP67 rated battery

TSL + HERITAGE

OPTIONAL ACCESSORIES

L06001012	Power splitter 2 Way - 1M-2F -1.5 metre (59")
L06001008	Power splitter 3 Way - 1M-3F - 1.5 metre (59")
L06009016	Extension cable 1 metre (39 $\frac{1}{2}$ ")
L06009032	Extension cable 4 metre (157 $\frac{1}{2}$ ")
L09510073	700mm flexi hose - $\frac{1}{2}$ " BSP thread
L0710005	Remote control for sensor tap
L08510012	Aerator - 1.89 litres per minute (0.5 GPM (US))
L08510034	Aerator - 6 litres per minute (1.59 GPM (US))
L130001	Aerator - Spray - 1.3 litres per minute (0.35 GPM (US))
L260025	6V battery pack

INSTALLATION REQUIREMENTS

Countertop cutout	30mm (1 $\frac{1}{4}$ ")
Maximum countertop thickness	30mm (1 $\frac{1}{4}$ ")
Electrical supply	3amp fused spur to be connected to IP68 transformer supplied; low voltage push fit connector to tap. For more reliable operation, it is not recommended that sensor taps are connected to an occupancy circuit. All connections must be in accord with the current local regulations in force.
Water supply	The Splash Lab sensor taps require at least 0.5bar dynamic water pressure to operate effectively; if 1 bar or more can be achieved the operation of the tap will be better. Applications with gravity-fed plumbing systems may require a booster pump to achieve the optimum operating pressure. The taps can be pressure tested to 10bar for commissioning purposes. All pipework must be thoroughly cleaned before connecting the tap to clear the pipes of any debris.
Access requirements	Solenoid and isolation valves must be accessible at for initial installation & commissioning and for ongoing and routine maintenance.
Washroom layout and planning	To prevent sensor malfunction, avoid installing sensor tap directly opposite other sensor taps/soap dispenser, other infra-red devices or reflective surfaces. The choice of other accessories in the room must also be considered, such as the waste outlet which can affect the sensor with light reflection. Care and consideration should also be given to the positioning of the lighting in the room, particularly in the case of taps with downward facing sensors.

COMPLIANCE

WRAS
BREEAM - 1 credit
LEED - 4 points
RoHS
CE
cUL

TSL + HERITAGE

RELATED DOCUMENTS

Installation and maintenance manual email: info.uk@thesplashlab.com

Warranty document

TECHNICAL DRAWING

